

48
212

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR Part 63 Subpart ZZZZ

☐ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221320 (at this time this is used for energies only)

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: City of Augusta

Facility name (if different): Waste Water treatment Plant

Facility (physical location) address: 101 S. 77 Hwy Augusta, KS 67010

My facility is a (please choose one): ☐ Major source ☒ Area source
☐ Synthetic minor

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

^b Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Owner name/title: City of Augusta_____

Owner/company address: 113 E. 6th Street P.O. Box 489 Augusta, KS 67010

Owner telephone number: (316)775-4527_____

Owner email address (if available): jsutton@augustagov.org_____

If the Operator information is different from the Owner, please provide the following:

Operator name/title: _____

Operator telephone number: _____

Operator email address (if available): _____

I hereby certify that the information presented herein is correct to the best of my knowledge.

Jim Sutton
(Signature)

AUGUST 26, 2010
(Date)

Jim Sutton / Power Plant Superintendent
(Name/title)

(316)775-4527
(Telephone No.)

Augusta Waste Water Plant

Unit	Manufacturer	Serial #	Model	Date of Manufacture	Generator KW	BHP	Fuel type	Stoke	KVA
1	Kohler	0679868	600R0Z04	2000	600	1120	Diesel	4	750

213

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112 _____

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: City of Augusta _____

Facility name (if different): Power Plant #2 _____

Facility (physical location) address: 615 E. 12th Street Augusta, KS 67010 _____

My facility is a (please choose one): ☐ Major source ☒ Area source
☐ Synthetic minor

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

^b Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Owner name/title: City of Augusta_____

Owner/company address: 113 E. 6th Street P.O. Box 489 Augusta, KS 67010

Owner telephone number: (316)775-4527_____

Owner email address (if available): jsutton@augustagov.org_____


If the Operator information is different from the Owner, please provide the following:

Operator name/title: _____

Operator telephone number: _____

Operator email address (if available): _____

I hereby certify that the information presented herein is correct to the best of my knowledge.


(Signature)


(Date)

Jim Sutton / Power Plant Superintendent
(Name/title)

(316)775-4527
(Telephone No.)

Augusta Power plant #2

Unit	Manufacturer	Serial #	Model	Date of Manufacture	Generator KW	BHP	Fuel type	Stoke	KVA
1	Worthington	VO3646	SWBGO	1968	4000	5556	Gas/Diesel	4	5000
2	Worthington	Vo3645	SWBGO	1968	4000	5556	Gas/Diesel	4	5000
3	Cooper Bessmer	7210	LSVB20-GDT	1981	6000	8312	Gas/Diesel	4	7500
4	FM/MAM B&W	1065088	18V 32/40 GF	2002	6720	9288	Gas/Diesel	4	8400